

Certificate




for European Product Safety

Reference No. 1808557

Sub-miniature fuse-link

Type designation	RST
Certificate holder	BEL FUSE 8/F., Luk Hop Ind. Building 8 Luk Hop Street San Po Kong, Kowloon HONG KONG
The product complies with the standard(s)	EN 60127-3:2015
Date of expiry	25 May 2023
EU Directive information	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Paul Klemets	Date	25 May 2018 Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

550

**Intertek
Appendix**

Reference No. 1808557

Technical data

Type designation	RST
Rated voltage (V)	AC 250 V
Rated current (A)	80, 100, 125, 160, 200, 250, 315, 400, 500, 630 and 800 mA
Standard sheet	1, 1.25, 1.6, 2, 2.5, 3.15, 4 and 5A. 4
Brand name:	bel
Product information	Time-lag, low-breaking capacity. Rectangular shape.

Manufacturing site(s) Bel Fuse Ltd. Zhongshan Wing
Ming Electronic Limited
86, Du Xing Dong Road, Du Tou
South District, Zhongshan City
528455 Guangdong Province
CHINA

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1304797 dated 9 August 2013.

A new certificate has been issued on account of 5-years renewal and updated standard.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed


 Paul Klemets
Date 25 May 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

SSU