



Product	AC-DC Converter
Applicant	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Manufacturer	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Factory	Bel Power Solutions, s.r.o. Areal ZTS 924 01841 Dubnica nad Vahom Slovakia
Ratings	4 A 100-240V~ 50-60 Hz
Trade mark	
Model / Type Ref.	CPA200-4530G, CPA250-4530G, CPA250-4530S256G, CPA250-4530S383G
Principal characteristics	DC output ratings see the test report. The model name may be followed by 'C' indicating PCB coating, 'A' for faceplate without company logo, L for output latch, 'G' indicating RoHS version or SXXX or combinations of the different options (X is alphanumeric character that denotes customer specific changes that do not impact safety requirements))
A sample of the product was tested and found to be in conformity with	ITAV EN IEC 62368-1:2020;A11
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	This certificate replaces the certificate issued 19-08-2020, due to the correction of the misprint. Compliance with requirements regarding building-in, protection against electric shock and Electromagnetic Compatibility (EMC) must be checked when the equipment is built-in a completed product or forms a part of a complete system.
Additional model(s)	No additional models

Date of issue 24-08-2020



Juan Z. Saussey
Certification Department

Nemko AS

Philip Pedersens vei 11, 1366 Lysaker, Norway
TEL +47 22 96 03 30 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532